

要求水準書添付資料23 運転帳票データ

1.ごみ処理量

2022年

月	ごみ投入量(t)			
	1号炉	2号炉	3号炉	計
	WQ100	WQ200	WQ300	WQ402
4	0.0	1,054.4	1,066.0	2,120.3
5	0.0	1,111.3	1,130.2	2,241.5
6	0.0	949.3	977.6	1,927.0
7	0.0	1,144.1	1,133.5	2,277.6
8	0.0	976.9	1,008.2	1,985.0
9	510.2	1,010.2	1,021.8	2,542.2
10	927.8	928.6	948.1	2,804.5
11	968.3	791.1	558.1	2,317.5
12	966.7	869.3	889.4	2,725.4
1	676.7	442.1	728.5	1,847.3
2	836.3	309.8	862.4	2,008.4
3	1,032.7	685.8	1,019.8	2,738.2
年平均	493.2	856.1	945.3	2,294.6
年最大	1,032.7	1,144.1	1,133.5	2,804.5
年最小	0.0	309.8	558.1	1,847.3
合計	5,918.6	10,272.8	11,343.5	27,534.9

2023年

月	ごみ投入量(t)			
	1号炉	2号炉	3号炉	計
	WQ100	WQ200	WQ300	WQ402
4	789.9	865.9	976.6	2,632.4
5	848.5	830.8	845.4	2,524.7
6	1,031.1	501.0	874.3	2,406.4
7	953.6	659.7	879.1	2,492.5
8	767.1	792.1	870.7	2,430.0
9	733.2	877.3	960.6	2,571.1
10	914.3	149.4	874.6	1,938.2
11	903.7	586.1	744.0	2,233.9
12	972.9	1,076.8	770.2	2,819.8
1	638.2	1,002.8	1,022.4	2,663.4
2	432.0	632.0	634.2	1,698.2
3	822.9	818.1	848.6	2,489.6
年平均	817.3	732.7	858.4	2,408.3
年最大	1,031.1	1,076.8	1,022.4	2,819.8
年最小	432.0	149.4	634.2	1,698.2
合計	9,807.4	8,792.0	10,300.7	28,900.1

2024年

月	ごみ投入量(t)			
	1号炉	2号炉	3号炉	計
	WQ100	WQ200	WQ300	WQ402
4	992.2	755.0	1,069.0	2,816.2
5	900.8	849.6	921.6	2,672.0
6	745.8	959.2	649.2	2,354.1
7	501.5	1,060.0	1,128.2	2,689.7
8	513.6	841.8	789.1	2,144.5
9	757.3	901.4	899.2	2,557.9
10	766.8	578.2	977.1	2,322.1
11	926.3	754.0	354.8	2,035.1
12	849.0	975.6	811.1	2,635.7
1	710.6	712.8	749.7	2,173.2
2	364.1	752.2	805.7	1,921.9
3	768.4	817.8	865.6	2,451.8
年平均	733.0	829.8	835.0	2,397.9
年最大	992.2	1,060.0	1,128.2	2,816.2
年最小	364.1	578.2	354.8	1,921.9
合計	8,796.5	9,957.5	10,020.2	28,774.2

2.消石灰使用量

単位：kg

2022年	244,240
2023年	275,090
2024年	314,570

3.煙突排ガス塩化水素濃度、酸素濃度

2022年

月	H C L (ppm)			O 2 (%)		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
	HCLi101A	HCLi201A	HCLi301A	O2i102	O2i202	O2i302
4	0.0	37.2	56.2	0.0	14.0	12.1
5	0.0	38.2	57.1	0.0	14.2	11.7
6	0.0	29.9	47.7	0.0	12.3	10.0
7	0.0	37.4	40.8	0.0	14.2	12.1
8	0.0	27.4	31.3	0.0	12.8	10.4
9	24.9	31.7	38.9	5.9	13.7	11.0
10	45.3	32.6	45.7	10.7	12.5	10.0
11	47.0	25.8	28.4	11.9	10.9	6.1
12	38.3	29.6	35.0	11.8	12.0	9.7
1	22.2	12.9	19.1	7.7	5.7	7.8
2	33.3	10.8	30.2	10.5	4.6	10.5
3	39.7	25.2	33.2	12.4	9.4	12.3
年平均	20.9	28.2	38.6	5.9	11.4	10.3
年最大	47.0	38.2	57.1	12.4	14.2	12.3
年最小	0.0	10.8	19.1	0.0	4.6	6.1
合計	----	----	----	----	----	----

2023年

月	H C L (ppm)			O 2 (%)		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
	HCLi101A	HCLi201A	HCLi301A	O2i102	O2i202	O2i302
4	28.6	30.5	35.0	9.7	12.4	12.1
5	43.2	41.2	43.0	9.9	11.2	9.8
6	32.6	9.4	25.1	12.0	6.3	10.0
7	29.4	16.5	24.6	10.2	8.3	9.6
8	28.5	29.8	31.6	8.9	10.1	10.3
9	26.1	29.5	26.2	8.6	11.8	11.6
10	42.3	5.2	35.6	11.0	2.1	11.1
11	33.8	22.8	20.4	10.9	6.9	9.4
12	34.5	45.3	29.5	11.8	12.7	8.9
1	17.7	37.2	32.0	6.8	10.3	10.9
2	21.4	53.8	47.9	6.6	9.7	10.1
3	30.1	32.2	28.9	9.9	9.7	10.0
年平均	30.7	29.5	31.7	9.7	9.3	10.3
年最大	43.2	53.8	47.9	12.0	12.7	12.1
年最小	17.7	5.2	20.4	6.6	2.1	8.9
合計	----	----	----	----	----	----

2024年

月	H C L (ppm)			O 2 (%)		
	1号炉	2号炉	3号炉	1号炉	2号炉	3号炉
	HCLi101A	HCLi201A	HCLi301A	O2i102	O2i202	O2i302
4	47.4	49.1	53.7	12.1	8.8	12.5
5	44.0	48.0	44.8	10.8	10.0	10.8
6	27.8	32.2	20.9	9.5	11.2	7.4
7	13.6	28.2	24.5	5.7	11.7	12.4
8	11.5	24.5	21.7	6.7	10.2	10.0
9	27.3	37.2	31.8	10.0	11.3	12.1
10	21.2	16.2	26.6	9.9	7.2	12.4
11	40.9	34.1	16.5	13.4	9.9	4.6
12	31.2	42.8	40.0	11.6	12.9	10.0
1	22.9	28.3	27.7	9.3	9.4	8.4
2	11.2	23.9	29.0	4.9	10.5	10.5
3	22.8	23.6	27.0	9.6	10.5	10.7
年平均	26.8	32.3	30.4	9.5	10.3	10.2
年最大	47.4	49.1	53.7	13.4	12.9	12.5
年最小	11.2	16.2	16.5	4.9	7.2	4.6
合計	----	----	----	----	----	----

ごみ処理日報（5 / 9）

2025年06月06日 金曜日

大村市環境センター

時刻	重 油 (l)												排ガス流量 (m3/hN)		
	助燃バーナ				再燃バーナ				補助 重油 使用量 FIQ401B	発電機 重油 使用量 FIQ401A	計	貯留槽 レベル m LI403	1号炉 FIC105	2号炉 FIC205	3号炉 FIC305
	1号炉 FIQ101	2号炉 FIQ201	3号炉 FIQ301	計	1号炉 FIQ102	2号炉 FIQ202	3号炉 FIQ302	計							
1:00	0	0	0	0	0	0	0	0	0	2	2	0.763	34,291	33,775	35,569
2:00	0	0	0	0	0	0	0	0	0	2	2	0.762	32,661	36,121	35,641
3:00	0	0	0	0	0	0	0	0	0	1	1	0.762	32,771	35,757	37,005
4:00	0	0	0	0	0	0	0	0	0	4	4	0.762	33,562	35,206	37,735
5:00	0	0	0	0	0	0	0	0	0	1	1	0.762	35,349	33,829	36,439
6:00	0	0	0	0	0	0	0	0	0	2	2	0.762	32,888	35,760	38,193
7:00	0	0	0	0	0	0	0	0	0	0	0	0.762	34,032	35,812	36,204
8:00	0	0	0	0	0	0	0	0	0	2	2	0.763	34,962	35,364	38,166
9:00	0	0	0	0	0	0	0	0	0	2	2	0.763	33,702	35,949	37,886
10:00	0	0	0	0	0	0	0	0	0	5	5	0.763	33,143	35,001	34,876
11:00	0	0	0	0	0	0	0	0	0	7	7	0.763	32,797	36,153	35,599
12:00	0	0	0	0	0	0	0	0	0	2	2	0.764	34,110	36,001	34,555
13:00	0	0	0	0	0	0	0	0	0	0	0	0.765	34,515	34,539	35,755
14:00	0	0	0	0	0	0	0	0	0	2	2	0.765	34,008	33,534	35,385
15:00	0	0	0	0	0	0	0	0	0	0	0	0.765	33,802	32,776	36,947
16:00	0	0	0	0	0	0	0	0	0	0	0	0.765	32,248	35,565	33,899
17:00	0	0	0	0	0	0	0	0	0	0	0	0.764	34,515	31,753	34,843
18:00	0	0	0	0	0	0	0	0	0	1	1	0.764	32,908	32,775	35,412
19:00	0	0	0	0	0	0	0	0	0	1	1	0.764	34,150	34,419	35,555
20:00	0	0	0	0	0	0	0	0	0	0	0	0.763	33,036	33,911	34,972
21:00	0	0	0	0	0	0	0	0	0	0	0	0.764	31,349	33,071	34,797
22:00	0	0	0	0	0	0	0	0	0	1	1	0.764	33,372	34,303	36,939
23:00	0	0	0	0	0	0	0	0	0	1	1	0.764	32,023	34,838	35,585
24:00	0	0	0	0	0	0	0	0	0	0	0	0.764	32,746	32,698	36,481
日平均	0	0	0	0	0	0	0	0	0	2	2	0.763	33,456	34,538	36,018
日最大	0	0	0	0	0	0	0	0	0	7	7	0.765	35,349	36,153	38,193
日最小	0	0	0	0	0	0	0	0	0	0	0	0.762	31,349	31,753	33,899
合計	0	0	0	0	0	0	0	0	0	36	36	---	---	---	---

所長	係長	係	係 員

時刻	ごみ投入量(t)				温 度 (℃)											
	1 号炉	2 号炉	3 号炉	計	炉出口			ガス冷却出口			B・F 入口ガス			誘引F 入口ガス		
					1 号炉	2 号炉	3 号炉	1 号炉	2 号炉	3 号炉	1 号炉	2 号炉	3 号炉	1 号炉	2 号炉	3 号炉
					WQ100	WQ200	WQ300	TIC101	TIC201	TIC301	TIC102	TIC202	TIC302	TIC103	TIC203	TIC303
1:00	2.07	1.04	1.05	4.16	864	903	889	377	353	370	201	200	203	179	181	184
2:00	1.03	1.04	1.08	3.15	882	943	869	354	345	365	198	207	200	181	185	183
3:00	0.92	2.08	2.04	5.04	900	919	911	398	373	370	200	205	205	179	183	184
4:00	2.07	2.08	0.98	5.13	912	893	904	363	373	383	203	208	206	182	184	184
5:00	1.07	1.05	1.13	3.25	865	874	867	379	315	394	205	203	202	181	187	184
6:00	1.08	1.13	2.21	4.42	800	898	904	328	368	388	204	207	212	185	184	189
7:00	2.37	2.31	1.11	5.79	855	880	831	339	345	344	207	204	207	185	187	189
8:00	1.15	1.13	2.41	4.69	923	888	840	377	411	375	201	206	211	180	181	188
9:00	0.93	1.17	1.09	3.19	927	898	877	371	386	380	202	207	211	182	181	187
10:00	1.50	1.03	1.03	3.56	885	889	894	363	363	371	201	209	203	181	187	186
11:00	1.06	2.02	1.04	4.12	910	920	847	374	377	359	203	206	205	180	185	185
12:00	0.98	2.07	1.03	4.08	892	873	888	368	365	370	203	209	203	182	187	183
13:00	2.09	1.06	2.09	5.24	885	919	894	365	357	413	206	203	205	184	184	183
14:00	1.80	1.92	1.78	5.50	924	942	872	394	369	376	202	202	204	179	184	185
15:00	1.01	1.03	1.04	3.08	885	835	896	351	375	376	202	196	210	182	178	187
16:00	2.06	2.03	1.05	5.14	855	915	897	346	365	413	198	207	200	181	183	181
17:00	1.05	1.05	2.12	4.22	931	840	868	377	366	384	204	194	201	181	178	181
18:00	1.66	0.87	0.86	3.39	868	892	884	387	365	378	200	199	201	179	179	181
19:00	0.93	1.70	1.66	4.29	922	897	909	381	390	394	202	204	203	180	180	181
20:00	1.81	0.91	0.87	3.59	841	934	864	378	408	376	198	199	202	177	178	182
21:00	0.84	1.67	1.73	4.24	863	940	893	377	385	398	197	200	200	177	178	180
22:00	1.87	2.11	2.24	6.22	875	921	929	365	394	361	199	203	204	179	177	184
23:00	2.21	1.10	1.16	4.47	907	904	836	352	380	327	198	205	203	181	182	186
24:00	1.30	1.30	1.16	3.76	902	866	907	383	355	370	204	198	207	180	180	186
日平均	1.45	1.45	1.42	4.32	886	899	882	369	370	376	202	203	205	181	182	184
日最大	2.37	2.31	2.41	6.22	931	943	929	398	411	413	207	209	212	185	187	189
日最小	0.84	0.87	0.86	3.08	800	835	831	328	315	327	197	194	200	177	177	180
合計	34.86	34.90	33.96	103.72	----	----	----	----	----	----	----	----	----	----	----	----